



District Level Water Quality Testing and Monitoring Laboratory

Uttarakhand Jal Sansthan, Pithoragarh

Ph (O): दूरभाष (काठ) 05964(225237)

E-mail: eeptujs@gmail.com

TEST REPORT

Name and Address of Organization/ Customer	Manager Don Bosco School Rai, Pithoragarh.		
Test Report ID	256/UJS/DLWQTML/2025-26	Reporting Date	11/03/2026
Date and Time of Sample Received:	09/03/26 & 01:15 PM	Sample Location	Don Bosco School Rai,(RO) Pithoragarh.
Product Description	Drinking Water	Sample Collected by	Customer
Reference Sample Identification:	DLWQTML/UJS/2026-68	Duration of Analysis	09/03/2026 to 11/03/2026


SN	Parameters	Test Method	Result	Requirement (Acceptable Limit) As per (IS 10500:2012)	Permissible Limit (IS 10500:2012) in the Absence of alternative source
(A) Organoleptic and Physical Parameters					
1.	pH at 25°C	IS 3025 (Part 11)	7.87	6.5 to 8.5	No Relaxation
2.	Total Dissolved Solids (TDS), at 180°C mg/L	IS 3025 (Part 16)	250	500Max	2000Max
3.	Turbidity, NTU	IS 3025 (Part 10)	Less Than 0.5	1Max	5Max
4.	Colour, CU	IS 3025 (Part 4)	1	5Max	15Max
5.	Odour	IS 3025 (Part 5)	Agreeable	Agreeable	Agreeable
(B) General Parameters Concerning Substances					
6.	Total Alkalinity (as CaCO ₃), mg/L	IS 3025 (Part 23)	164	200Max	600Max
7.	Total Hardness (as CaCO ₃), mg/L	IS 3025 (Part 21)	169.2	200Max	600Max
8.	Calcium as Ca, mg/l	IS 3025 (Part 40)	33.12	75Max	200Max
9.	Chloride as Cl, mg/L	IS 3025 (Part 32)	25.3	250Max	1000Max
10.	Magnesium as Mg, mg/l	APHA 24 th Ed-3500- Mg Method B: 2023 (Calculation Method)	20.99	30 Max	100 Max

Note:-

1. The results listed refer only to tested sample and applicable parameters
2. This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after Seven days from the date of issue of test certificate, unless otherwise agreed with customer.
4. The results apply to the sample as received
5. The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer

**** End of Report****

Review and Authorized By


(Er. Suresh Joshi)
Technical Manager, Lab



**District Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, Pithoragarh**

Ph (O): दूरभाष (काठ) 05964(225237)
E-mail: eeptujs@gmail.com

TEST REPORT

Name and Address of Organization/ Customer	Manager Don Bosco School Rai, Pithoragarh.		
Test Report ID	256A/UJS/DLWQTML/2025-26	Reporting Date	11/03/2026
Date and Time of Sample Received:	09/03/26 & 01:15 PM	Sample Location	Don Bosco School Rai, (RO) Pithoragarh.
Product Description	Drinking Water	Sample Collected by	Customer
Reference Sample Identification:	DLWQTML/UJS/2026-68	Duration of Analysis	09/03/2026 to 11/03/2026

SN	Parameters	Test Method	Results	Requirement (Acceptable Limit) As per (IS 10500:2012)	Permissible Limit (IS 10500:2012) in the Absence of alternative source
----	------------	-------------	---------	--	--

(C) General Parameters Concerning Substances

1.	Fluoride, mg/L	IS 3025 (Part60/Sec 1)	Less than 0.2	1.0 Max	1.5 Max
2.	Nitrate, mg/L	IS 3025 (Part34/Sec 1)	1.20	45 Max	No Relaxation
3.	Sulfate, mg/L	IS 3025 (Part24/Sec 1)	Less than 05	200 Max	400 Max
4.	Iron (as Fe), mg/L	IS 3025 (Part 53) : 2024	Less Than 0.1	1.00 Max	No Relaxation
5.	Residual Free Chlorine, mg/L	APHA 23rd Ed.-4500-CL-G	ND	0.2 Min	1.00 Max


(D) Bacteriological Parameters

SN	Parameters	Test Method	Results	Shall Not be Detected in 100 ml Sample	Shall Not be Detected in 100 ml Sample
1.	Total Coliform, /100ml	APHA 23rd Ed.-9223-B	Absent	Absent	Absent

- Note:-
1. The results listed refer only to tested sample and applicable parameters
 2. This certificate is not to be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
 3. The samples will be destroyed after Seven days from the date of issue of test certificate, unless otherwise agreed with customer.
 4. The results apply to the sample as received
 5. The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer

**** End of Report****

Review and Authorized By


(Er. Suresh Joshi)

Technical Manager, Lab

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 687 | जल परिक्षण 132

Dated: 13/03/2026

It is certified that an inspection team headed by Executive Engineer, UJS, Pithoragarh

(Name of Officers with designation) from Uttarakhand Jal Santha Lab, PHED

inspected the Don Bosco School, Rai, Pithoragarh

(Name & Address of the school) on 9-03-2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 25/1/HJS/DLWQ/17/12/25/26 (dated 11/03/2026)

of Uttarakhand Jal Santha Laboratory (PHED Lab) certified that


the Don Bosco School, Rai, Pithoragarh (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 10/03/2026

Signature with Seal: 

Name आध्यात्मिक अभियन्ता

Designation उत्तराखण्ड जल संस्थान


Name & Address of the Office / Department : पितौरगढ़

To Don Bosco School, Rai, Pithoragarh

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies


Manager
Don Bosco School
Pithoragarh (U.K.)


Principal
Don Bosco School
Pithoragarh (U.K.)